

ORIGINAL



0000168032

Steve Wene, State Bar No. 019630  
MOYES SELLERS & HENDRICKS LTD.  
1850 N. Central Ave., Suite 1100  
Phoenix, Arizona 85004  
Telephone: 602-604-2141  
e-mail: swene@law-msh.com

RECEIVED

2015 DEC 30 P 4: 24

AZ CORP COMMISSION  
DOCKET CONTROL

**BEFORE THE ARIZONA CORPORATION COMMISSION**


**COMMISSIONERS**

SUSAN BITTER SMITH, CHAIRMAN  
BOB STUMP  
BOB BURNS  
TOM FORESE  
DOUG LITTLE

Arizona Corporation Commission

**DOCKETED**

DEC 30 2015



**IN THE MATTER OF THE  
APPLICATION OF CLEAR SPRINGS  
UTILITY CO., INC., FOR AN  
INCREASE IN RATES**

**and**

**IN THE MATTER OF THE  
APPLICATION OF CLEAR SPRINGS  
UTILITY CO., INC., FOR AUTHORITY  
TO INCUR LONG-TERM DEBT**


Docket Nos. W-01689A-11-0401  
WS-01689A-11-0402

**NOTICE OF COMPLIANCE RE  
FILING WATER LOSS REPORT**

Pursuant to Decision 74037 ("Decision"), Clear Springs Utility Co. hereby files  
its water loss report set forth in Attachment 1.

1 RESPECTFULLY SUBMITTED this 30<sup>th</sup> day of December, 2015.

2 **MOYES SELLERS & HENDRICKS LTD.**

3  
4 

5 Steve Wene

6  
7 Original and 13 copies of the foregoing  
8 filed this 30<sup>th</sup> day of December, 2015 with:

9 Docket Control  
10 Arizona Corporation Commission  
11 1200 West Washington  
12 Phoenix, Arizona 85007

13   
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

# ATTACHMENT 1

12/28/2015

DATA SHEET

ARIZONA CORPORATION COMMISSION  
DOCKET CONTROL  
1200 W. WASHINGTON  
PHOENIX, ARIZONA 85007

RE: COMPLIANCE WITH DECISION #74037  
DOCKET #W-01689A-11-0401 &  
W-01689A-11-0402

Clear Springs Utility Company, Inc.  
P.O. BOX 85160  
TUCSON, ARIZONA 85754  
(520) 623-5172

Clear Springs Utility Company

Water Data 2015

	2014		2014		2015		2015	
	Water		Water		Water		Water	
Month	Sold		Pumped	Loss	Pumped	Loss	Pumped	Loss
December	1,808,524		1,992,765	9.25%				
January	2,129,773		2,332,757	8.70%				
February	2,105,680		2,287,696	7.96%				
March	2,601,146		3,469,100	25.02%				
April	2,756,584		3,741,300	26.32%				
May	4,487,373		4,651,150	3.52%				
June	5,497,777		6,345,400	13.36%				
July	3,630,575		4,160,200	12.73%				
August	3,256,940		4,060,500	19.79%				
Sept.	2,321,610		2,723,600	14.76%				
Oct.	1,983,351		2,193,100	9.56%				
Nov.	2,618,530		3,280,500	20.18%				
Dec.	1,771,690		2,036,200	12.99%				
				14.16%				
Rounded to the nearest 1000								
	2015		2015		2015		2015	
	Water		Water		Water		Water	
Month	Sold		Pumped	Loss	Pumped	Loss	Pumped	Loss

Multiple leaks  
Multiple leaks

Large leak

Multiple leaks

January	1,878,000	3,021,000	37.84%	Multiple Leaks - Christmas Tree & Dale
February	1,584,000	1,599,000	0.94%	
March	1,848,000	3,361,000	45.02%	Fire Hydrant leaking on Golf Course long time. 90,000 stolen.
April	2,337,000	3,169,000	26.25%	
May	3,664,000	4,657,000	21.32%	3/25 leaks at 1210 geneva.
June	3,293,000	4,022,000	18.13%	Recovering from last months leaks.
July	3,109,000	4,014,000	23.00%	Recovering from previous months leaks.
August	3,031,000	4,085,000	26.00%	See attached report
Sept.	2,645,000	3,060,000	14.00%	See attached report
Oct.	2,458,000	3,420,000	28.00%	See attached report
Nov.	2,406,000	2,940,000	18.00%	See attached report
Dec.	1,624,000	2,276,000	29.00%	See attached report
			23.96%	

# Monthly Water Loss Report

Water Company: **Clear Springs Utility**  
Routes: **All - Combined**  
For the Month of: **July-15**

Water Produced this month: **4,014,000** gallons  
Water Purchased this month: **0** gallons

**A: Total Water Produced = 4,014,000 gallons**

**Total Water Sold = 3,109,000 gallons**

**B: Difference: (Produced - Sold) = 905,000 gallons**

**% Difference (B/A) = Total Water Loss: 23 %**

## Gallons of Water Accounted For:

Breaks (Estimated Total):	<b>192,000</b> gallons
Hydrant or DVA Flushing (Estimated):	<b>0</b> gallons
Storage Tank Overflow:	<b>0</b> gallons
Other (Estimated):	<b>0</b> gallons
Wastewater Treatment Plant Use:	<b>0</b> gallons
Fire Department Use:	<b>0</b> gallons
Adjustment + / -:	<b>-30,000</b> gallons

**C: Total Gallons Accounted For = 162,000 gallons**

**Loss: Unaccounted-for Water: (B-C) = 743,000 gallons**

**% Loss (B-C)/A = Unaccounted for Loss: 19 %**

Township: 7/2/15 Leak at Sunsites Trailer Park on Tracy Road. (Approx 172000 gallons) 7/9/15 Leak at 105 Frontage Road (Approx. 3000 gallons) 7/9/15 Leak at 1117 Christmas Tree Lane (Approx. 2000 gallons). 7/9/15 Leak at #19 Bulk Station (Approx. 15000 gallons).


# Monthly Water Loss Report

Water Company: **Clear Springs Utility**  
Routes: **All - Combined**  
For the Month of: **August-15**

Water Produced this month: **4,085,000** gallons  
Water Purchased this month: **0** gallons

**A: Total Water Produced = 4,085,000 gallons**

**Total Water Sold = 3,031,000 gallons**

**B: Difference: (Produced - Sold) = 1,054,000 gallons**

**% Difference (B/A) = Total Water Loss: 26%**

## Gallons of Water Accounted For:

Breaks (Estimated Total):	<b>0</b> gallons
Hydrant or DVA Flushing (Estimated):	<b>0</b> gallons
Storage Tank Overflow:	<b>0</b> gallons
Other (Estimated):	<b>0</b> gallons
Wastewater Treatment Plant Use:	<b>0</b> gallons
Fire Department Use:	<b>0</b> gallons
Adjustment + / -:	<b>0</b> gallons

**C: Total Gallons Accounted For = 0 gallons**

**Loss: Unaccounted-for Water: (B-C) = 1,054,000 gallons**

**% Loss (B-C)/A = Unaccounted for Loss: 26%**

7/29/2015 leak at 210 Ford

# Monthly Water Loss Report

Water Company: **Clear Springs Utility**  
Routes: **All - Combined**  
For the Month of: **September-15**

Water Produced this month: **3,060,000** gallons  
Water Purchased this month: **0** gallons

**A: Total Water Produced = 3,060,000 gallons**

**Total Water Sold = 2,645,000 gallons**

**B: Difference: (Produced - Sold) = 415,000 gallons**

**% Difference (B/A) = Total Water Loss: 14%**

## Gallons of Water Accounted For:

Breaks (Estimated Total):	<b>0</b> gallons
Hydrant or DVA Flushing (Estimated):	<b>0</b> gallons
Storage Tank Overflow:	<b>0</b> gallons
Other (Estimated):	<b>0</b> gallons
Wastewater Treatment Plant Use:	<b>0</b> gallons
Fire Department Use:	<b>0</b> gallons
Adjustment + / -:	<b>0</b> gallons

**C: Total Gallons Accounted For = 0 gallons**

**Loss: Unaccounted-for Water: (B-C) = 415,000 gallons**

**% Loss (B-C)/A = Unaccounted for Loss: 14%**




# Monthly Water Loss Report

Water Company: **Clear Springs Utility**  
Routes: **All - Combined**  
For the Month of: **October-15**

Water Produced this month: **3,420,000** gallons  
Water Purchased this month: **0** gallons

**A: Total Water Produced = 3,420,000 gallons**

**Total Water Sold = 2,458,000 gallons**

**B: Difference: (Produced - Sold) = 962,000 gallons**

**% Difference (B/A) = Total Water Loss: 28%**

## Gallons of Water Accounted For:

Breaks (Estimated Total):	<b>0</b> gallons
Hydrant or DVA Flushing (Estimated):	<b>0</b> gallons
Storage Tank Overflow:	<b>0</b> gallons
Other (Estimated):	<b>0</b> gallons
Wastewater Treatment Plant Use:	<b>0</b> gallons
Fire Department Use:	<b>0</b> gallons
Adjustment + / -:	<b>0</b> gallons

**C: Total Gallons Accounted For = 0 gallons**

**Loss: Unaccounted-for Water: (B-C) = 962,000 gallons**

**% Loss (B-C)/A = Unaccounted for Loss: 28%**

Line Break at 1205 Flynn Jans Court-9/18/2015

# Monthly Water Loss Report

Water Company: **Clear Springs Utility**  
Routes: **All - Combined**  
For the Month of: **November-15**

Water Produced this month: **2,940,000** gallons  
Water Purchased this month: **0** gallons

**A: Total Water Produced = 2,940,000 gallons**

**Total Water Sold = 2,406,000 gallons**

**B: Difference: (Produced - Sold) = 534,000 gallons**

**% Difference (B/A) = Total Water Loss: 18%**

## Gallons of Water Accounted For:

Breaks (Estimated Total):	<b>0</b>	gallons
Hydrant or DVA Flushing (Estimated):	<b>68,571</b>	gallons
Storage Tank Overflow:	<b>0</b>	gallons
Other (Estimated):	<b>0</b>	gallons
Wastewater Treatment Plant Use:	<b>0</b>	gallons
Fire Department Use:	<b>0</b>	gallons
Adjustment + / -:	<b>0</b>	gallons

**C: Total Gallons Accounted For = 68,571 gallons**

**Loss: Unaccounted-for Water: (B-C) = 465,429 gallons**

**% Loss (B-C)/A = Unaccounted for Loss: 16%**

Leaks throughout system. Flushing Sewer (Approx. 68,571 gallons).

# Monthly Water Loss Report

Water Company: **Clear Springs Utility**  
Routes: **All - Combined**  
For the Month of: **December-15**

Water Produced this month: **2,276,000** gallons  
Water Purchased this month: **0** gallons

**A: Total Water Produced = 2,276,000 gallons**

**Total Water Sold = 1,624,000 gallons**

**B: Difference: (Produced - Sold) = 652,000 gallons**

**% Difference (B/A) = Total Water Loss: 29%**

## Gallons of Water Accounted For:

Breaks (Estimated Total):	<b>0</b> gallons
Hydrant or DVA Flushing (Estimated):	<b>70,000</b> gallons
Storage Tank Overflow:	<b>0</b> gallons
Other (Estimated):	<b>0</b> gallons
Wastewater Treatment Plant Use:	<b>0</b> gallons
Fire Department Use:	<b>0</b> gallons
Adjustment + / -:	<b>0</b> gallons

**C: Total Gallons Accounted For = 70,000 gallons**

**Loss: Unaccounted-for Water: (B-C) = 582,000 gallons**

**% Loss (B-C)/A = Unaccounted for Loss: 26%**

Township: Line Break 1010 Christmas Tree (Approx. 70,000 gallons)

Rt. 2 Well #6: No surface leaks found - will monitor.